



Shasta County

DEPARTMENT OF RESOURCE MANAGEMENT
1855 Placer Street, Redding, CA 96001

Richard W. Simon, AICP
Director

Dale J. Fletcher, CBO
Assistant Director

August 23, 2016

Lakeshore Villa RV Park
20672 Lakeshore Drive
Lakehead, CA 96051

CITATION 01_75_16C_007_4500080_22 FOR WATER QUALITY FAILURE –
LAKESHORE VILLA RV PARK PUBLIC WATER SYSTEM, NO. 4500080

This letter is to inform you that the Lakeshore Villa RV Park Water System failed to meet bacteriological domestic water quality standards for August 2016. The number of positive bacteriological samples exceeds the limits of Title 22, California Code of Regulations (CCR), Article 3, Section 64426.1(b). Five of nine water samples collected between August 1 and August 11, 2016, were positive for total coliform bacteria. The standard is that no more than one sample per month may do so.

Section 64464.1, Title 22, CCR, specifies that the Shasta County Environmental Health Division (SCEHD) shall direct the water supplier to provide public notification. For the August 2016 water quality failure, the water system shall give notice by posting a notification in conspicuous locations throughout the area served by the water system and by one or more of the following methods to reach persons not likely to be reached by the previous method: publication in local newspaper, email message to customers (employees and students), posting on the internet or by direct delivery to each customer. The enclosed notice titled "Important Information about Your Drinking Water" is the public notice that you shall give to all water users and post to fulfill the above notification requirements.

Within 45 days of receipt of this letter, you are required to send this office a signed statement which indicates the date the notice was posted. Completing and returning the enclosed "Certification of Completion of Public Notification" form fulfills this requirement. Please also include what corrective action was taken to prevent such failures in the future and the cause of the failure if known.

Note that Section 116577 of the California Safe Drinking Water Act provides for the SCEHD to be reimbursed by the public water system for costs incurred for preparing and issuing public notifications to that system. In accordance with Section 116577, the water system will be billed for the preparation and issuance of this letter and notification. Approximately one 1/2-hour was spent preparing this letter and notification, and currently our costs are approximately \$65.73 per hour. You shall submit a check in the amount of \$32.87 to SCEHD.

☐ Suite 101
AIR QUALITY MANAGEMENT DISTRICT
530 225-5674
Fax 530 225-5237

☐ Suite 102
BUILDING DIVISION
530 225-5761
Fax 530 245-6168

☐ Suite 103
PLANNING DIVISION
530 225-5532
Fax 530 245-6168

☒ Suite 201
ENVIRONMENTAL HEALTH DIVISION
530 225-5787
Fax 530 225-5413

☐ Suite 200
ADMINISTRATION & COMMUNITY EDUCATION
530 225-5789
Fax 530 225-5807

Lakeshore Villa RV Park

Page 2

August 23, 2016

Please call me at 530/225-5787, Monday through Friday between 8:00 and 8:30 a.m., should you have any questions regarding this matter.

Sincerely,

A handwritten signature in cursive script, reading "Christy Gilbreath". The signature is written in dark ink and is positioned above the printed name and title.

Christy Gilbreath, R.E.H.S.

Registered Environmental Health Specialist

CG/pw

Enclosures